

EC DECLARATION OF CONFORMITY

Power Distribution Unit (PDU)

We
at
Schleifenbauer Products BV
Rietwaard 15, 5236 WC 's-Hertogenbosch, the Netherlands
tel: +31 73 5230256

in accordance with the following directives:

2006/95/EC The Low Voltage Directive
2004/108/EC The Electromagnetic Compatibility Directive

hereby declare that:

Equipment Power Distribution Unit (PDU)
Product ID All PDUs in the following product identification range: **S***fiopa**-*****
where **f** = [H,D,V,G,C]; **i** = [I, N, C, X, P, J, A]; **o** = [M, N, S, B]; **p** = [1,3], **a** = [1,3,6]
(see document: productID_v1.5 for more details on the product identification method)

The construction of the appliance is in accordance with the following harmonised standards:

LVD

EN-IEC 60950-1:2006 Information technology equipment - Safety
.../A1:2010
.../A12:2011

EMC

EN-IEC 61000-6-3:2007 Emission standard for residential, commercial and light-industrial environments

.../A1:2011
.../IS1:2011

EN-IEC 61000-3-2:2014 Limits for harmonic current emissions
EN-IEC 61000-3-3:2013 Limitation of voltage changes, voltage fluctuations and flicker
EN 55016-2-1:2014 Specification for radio disturbance and immunity measuring apparatus and methods
EN 55022:2011 Radio disturbance characteristics - Limits and methods of measurement
.../C1:2011

EN-IEC 61000-6-2:2005 Generic standards - Immunity for industrial environments

EN-IEC 61000-4-2:2009 Electrostatic discharge immunity test
EN-IEC 61000-4-3:2006 Radiated, radio-frequency, electromagnetic field immunity test
.../IS1:2009

.../A1:2008
.../A2:2010

EN-IEC 61000-4-4:2012 Electrical fast transient/burst immunity test
EN-IEC 61000-4-5:2014 Surge immunity test
EN-IEC 61000-4-6:2014 Immunity to conducted disturbances, induced by radio-frequency fields
EN-IEC 61000-4-11:2004 Voltage dips, short interruptions and voltage variations immunity tests

I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications.
The unit complies with all applicable Essential Requirements of the Directives. A name or reference of the customer may be engraved in the profile.

Signed by:

Name: A.S.L. Schuermans
Position: Chief Technology Officer
Done at: Rosmalen
On: 01-03-2015

**This declaration is intentionally unsigned.
Please contact Schleifenbauer Products if
you require a signed document.**

