

Accuracy Statement

SP-K-0052-001

The Schleifenbauer power distribution units (PDUs) have a billing grade accuracy of $\pm 1\%$ and are compliant with:

- EN 50470-3: class B
- EN 62053-21: class 1

Notes:

- Full test results on accuracy (Nmi-12200825-01) can be consulted upon request
- Immunity for DC harmonics only available on special order
- Schleifenbauer PDUs are *not* MID MI-003 approved but conform to its required accuracy

Name: Alain Schuermans
Function: Chief Technology Officer
Date: 01-10-2021

Signature:



Shipped from: Schleifenbauer Products B.V.
Rietwaard 15, 5236 WC
's-Hertogenbosch, The Netherlands
Tel: +31 (0)73 523 02 56
Fax: +31(0)73 521 23 83

Gebruiker: Alain Schuermans
Opgesteld door: Edward Goudsmits
Vrijgegeven door: Jan de Haan

Datum: 01/10/2021
Datum: 01/10/2021
Datum: 01/10/2021

Pagina: 1 van 1

Een geprinte kopie van dit document is geen beheerst document

